



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 14, 2016 NO.: RFI-169

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Domestic Water Heater Flue

Response Required By: June 21, 2016

Drawing / Spec Reference:

Information Requested:

The water heater manufacturer strongly recommends that the water heater intake and the exhaust be placed on the same face of the building, to avoid issues with wind patterns creating pressure fluctuations that could create serious issues with the functioning of the heater. Furthermore, the exhaust and intake would ideally be located within a few feet of each other, rather than several floors apart, due to possible air pressure variances on windy days.

Please advise if the domestic water heater intake and exhaust openings can be located within a few feet of each other, and on the same face of the building.

Response:

See RFI - 232 response.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: **Mark Schaefer**

Date: **08/31/2016**