



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 17, 2016 NO.: RFI-174

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Stacked HW Coil wiht Freeze Pump Piping Detail

Response Required By: June 24, 2016

Drawing / Spec Reference:

Information Requested:

The current HW coil wiht freeze pump piping detail is shown with a single coil.

Please provide a detail for the stacked HW heating coil with freeze pump piping detail. Are balancing valves required at each coil connection to get equal flow during freeze pump operation?

Response:

Provide balance valve (circuit setter) at each coil as required for proper balancing as specified in section 230600. Locate valves in return line of each coil.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: 

Date: 6/20/2016