



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 22, 2016 **NO.:** RFI-178

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: utilities above SIM lab

Response Required By: June 29, 2016

Drawing / Spec Reference:

Information Requested:

There is water, waste and vent piping located above the SIM lab 133B room. Is this acceptable? There is a pre-action fire protection system serving this room, which may have sensitive equipment in it.

Response:

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Piping will be reconfigured and a sheet metal trough pan is to be placed under the waste, vent and water piping within this room.

This will be addressed in an upcoming ASI.

Answered By: Mike Whitworth - WES

Date: July 10, 2016