



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: June 24, 2016 NO.: RFI-182

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Testing Duration of thru wall flashing splices

Response Required By: July 05, 2016

Drawing / Spec Reference:

Information Requested:

Please confirm if the testing duration identified in specification section 042000 3.11.A.4 can be revised to 30 minutes in lieu of 2 hours.

Response:

Proposed testing duration of 30 minutes is acceptable given on-site construction conditions reviewed with the Owner's enclosure consultant, George Crow.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Lynn Grossman

Date: 06.27.16