



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** June 24, 2016 **NO.:** RFI-183

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Sump Pump Power

Response Required By: July 01, 2016

Drawing / Spec Reference:

Information Requested:

The electrical drawings show power to Sump Pumps SP-1, SP-2, and Sp-3 but do not identify which panel they are being fed from, feeder size, or breaker size.
Also please confirm the sump pump locations shown on plumbing drawing sheet P0601.

Response: Sump pumps SP-1 and SP-2 serve the under floor drain tile system. They are located on Level 0.
Refer to plumbing drawing P0010, along column line 8, south of D.

SP-1 & SP-2 shall each be connected to a 15A-3P circuit breaker on panel BNH1 (26, 28, 30)
(32, 34, 36) #12AWG.

SP-3 shall be connected to a 20A-1P circuit breaker on panel BNL1 (6), #12AWG, this is cord and
plug connected.

Bill Shaw, WTA 6/25/16

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Cc: Kathy Bathe, Paric Corporation

Answered By: Mike Whitworth - WES

Date: June 25, 2016