



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 07, 2016	NO.: RFI-192
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Furring out Walls at Duct in Office

Response Required By: July 14, 2016

Drawing / Spec Reference:

Information Requested:

M0101.b shows a 12" duct coming above ceiling to the roof above mock exam room 114. No chase is shown in the rooms above for this duct. Please advise if a chase is to be added and provide details as needed. If the intent is to move this duct to the chase at B.3/2 the chase will need to be resized accordingly

Response:

ASI-009 is in process to address the enclosure of this exhaust duct . Duct center line should be located 9'-2" west of column line 2.6. Enclosure will be separate from enclosure at B.3 / 2

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 07.08.16