



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** July 07, 2016 **NO.:** RFI-193

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Pressure reducing valve

Response Required By: July 14, 2016

Drawing / Spec Reference:

Information Requested:

Detail 6/P502 does not show a pressure reducing valve for the main domestic water service. Is one required for this project? If so, where is it to be installed at?

Response:

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

A pressure reducing valve will be required.

This will be addressed in an upcoming ASI.

Answered By: Mike Whitworth

Date: July 22, 2016