



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: July 13, 2016 NO.: RFI-199

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Pier Cap Connections to rock at level 0

Response Required By: July 20, 2016

Drawing / Spec Reference:

Information Requested:

Please advise if there is to be any additional connection from pier cap to rock at level 0 where drilled piers were eliminated. If there is additional steel required, please try to utilize the reinforcing we have available for the drilled piers that were eliminated.

Response:

**DRILLED PIERS WERE KEPT IN PROJECT. THIS RFI IS A NON-ISSUE AT THIS TIME.
UNSUITABLE MATERIAL WAS LATER FOUND AND THE PIERS WERE REQUIRED
TO REMAIN PER CONTRACT DRAWINGS.**

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 8/8/2016