



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 14, 2016	NO.: RFI-200
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Backpan at CW locations

Response Required By: July 21, 2016

Drawing / Spec Reference:

Information Requested:

Please advise of design intent of backpan at CW locations. Is the backpan utilized for fire rating? A 2 hr fire rating can be achieved without the use of a backpan

Response:

Per conference call on 07/28/2016 discussing the merits of backpan, please retain backpan at all CW locations.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: KWA & CannonDesign

Date: 07/28/2016