



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 15, 2016	NO.: RFI-203
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Follow up clarifications for RFI 154

Response Required By: July 22, 2016

Drawing / Spec Reference:

Information Requested:

RFI 154 addresses the question "section 14/S0303 shows the plates starting and stopping (relative to the floors?)" with the response "TBD-Plate extend depends on aluminum window anchorage points to be selected by YII".

Please advise response for fabrication

The question "At the window head, section 9/S0302 calls for a tube and angle (6/S301 sim.) with the window opening 'below' (agrees with 4/A0402) – how/where do jamb plates terminate?" was responded to with "Head: Jamb terminates at slide anchor plate in Detail 1 Sheet A0452.

Sill: Jamb terminates at horizontal steel plate." 1/A0452 is a brick ledge detail.

Please advise if there is another detail to refer to.

Response:

SEE ATTACHED SKETCH. VERIFY WITH NGG THAT THIS DETAIL IS COMPATIBLE WITH THE CURTAINWALL DESIGN AT THE NORTH WALL.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 8/2/2016

1/2"x5"x8" BENT PLATE
EACH SIDE w/(2) 3/4" DIA.
THRU BOLTS IN VERTICAL
SLOTTED HOLES

T/STL = 139'-10 5/8"
verify w/NGG

TYP. 1/4
1/4

Level 04
130' - 8"

1/2" GAP IN PLATE

TYP.

TYP. 1/4 3-12
1/4 3-12

1/2" PLATE AT
WINDOW LOCATIONS
COORDINATE WITH
ARCH. DWGS.

Level 03
115' - 4"

1/2" GAP IN PLATE

HSS6x4x5/16 EACH END
OF STRIP WINDOWS

1/2" PLATE AT
WINDOW LOCATIONS
COORDINATE WITH
ARCH. DWGS.

1/2" PLATE ACROSS
BOT OF CURTAINWALL
B/STL = 103'-0 7/8"
verify w/NGG

Level 02
100' - 0"

14 FRAMING SECTION
3/4" = 1'-0"