



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

---

|                                |                            |                     |
|--------------------------------|----------------------------|---------------------|
| <b>REQUEST FOR INFORMATION</b> | <b>DATE:</b> July 18, 2016 | <b>NO.:</b> RFI-204 |
|--------------------------------|----------------------------|---------------------|

---

To: Cannon Design

---

Attn: Kelvin Patel

---

From: Paric Corporation

---

Requested By: Devin Gates

---

|               |                                                             |                    |
|---------------|-------------------------------------------------------------|--------------------|
| Project Name: | 15051-Webster University Interdisciplinary Science Building | Project No.: 15051 |
|---------------|-------------------------------------------------------------|--------------------|

---

Subject: Ceiling type in room 186

---

Response Required By: July 25, 2016

---

Drawing / Spec Reference:

---

**Information Requested:**

Please confirm the ceiling type in room 186 will be GWB-3 as in room 188.

**Response:**

This is not correct. Room 186 - Custodial Storage should have an exposed structure ceiling. Lights will be changed by ASI.

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 07.21.16