



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 18, 2016	NO.: RFI-205
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Provide additional details for WA type light fixture.

Response Required By: July 25, 2016

Drawing / Spec Reference:

Information Requested:

E0201.A shows WA type light fixtures which the schedule calls out as 4" wide x 5" deep x 4' light. Please confirm the intent is for the light to be mounted vertically and please provide details showing mounting heights required for wall.

Response:

Mount fixture vertically, centered on the wall. The ceiling height appears to be 8'-10". At this height, the bottom of fixture would be approximately 2'-5" AFF and the top of fixture 6'-5" AFF.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 7/28/16