



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 21, 2016	NO.: RFI-210
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Water piping for room 376

Response Required By: July 28, 2016

Drawing / Spec Reference:

Information Requested:

P0103.A

There does not appear to be any water piping serving what appears to be a sink in Room 376 Cold Room. Does this fixture receive water piping?

Response:

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

The Cold Room (376) is served with CW only, piping is shown on drawing P0103.A, and drawing P0409 Domestic Water Supply Riser - Lab waste 372B, Research 374A, Tussue Culture 374B and Cold Room 378.

Answered By: Mike Whitworth

Date: July 22, 2016