



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** July 21, 2016 **NO.:** RFI-212

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: ES-1 in room 389

Response Required By: July 28, 2016

Drawing / Spec Reference:

Information Requested:

There appears to possibly be an emergency fixture on the wall in Room 389 Bio Lab Prep Room A, but there is no water piping or fixture tag called out on Sheet P0103.A. Please clarify if there is a fixture to be installed here, and what type.

Response:

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

There is an Emergency Shower and mixing valve (ES-1/TMV-2) located in this room. Piping for this fixture was inadvertently not shown. Piping for this fixture and fixture tags are shown on the water supply riser diagram, refer to drawing P0405. Based on a line-item cost review of Addendum 2-4, page 6 of 7, it appears all emergency showers have been accounted for.

For clarity and continuity, this will be addressed in an upcoming ASI.

Answered By: Mike Whitworth - WES

Date: July 23, 2016