



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** July 27, 2016 **NO.:** RFI-219

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Free standing fire department connection

Response Required By: August 03, 2016

Drawing / Spec Reference:

Information Requested:

Neither the FP or the civil drawings identify the free standing fire department connection location. Please provide dimensions for coordination.

Response:

Generally, the FDC shall be located along the eastern edge of the existing parking lot west of the ISB construction, southeast corner. Coordinate location with the Civil Engineer.

This location was determined by the AHJ during the design phase. Verify location with the AHJ prior to installation.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Whitworth - WES

Date: July 30, 2016