



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: July 27, 2016	NO.: RFI-222
--------------------------------	----------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Follow up to RFI 150 pertaining to FP drain location

Response Required By: August 03, 2016

Drawing / Spec Reference:

Information Requested:

The response for RFI 150 stated the following;

The 2" main drain needs to drain to exterior of the building, not the area way. The discharge is to be located and directed to allow runoff away from the building. Consideration is to be given to prevent ground erosion or damage to the surrounding area by use of a concrete splash block, slab or other means. Coordinate location of drain with the architect, civil engineer, landscape architect and other building trades as required.

Suggestion: Please advise on correct location.

Response:

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

The design build Fire Suppression contractor should coordinate this with the Architect.

Answered By: Mike Whitworth

Date: August 05, 2016