



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** August 01, 2016 **NO.:** RFI-226

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Low Pressure Duct insulation

Response Required By: August 08, 2016

Drawing / Spec Reference:

Information Requested:

Insulation, liner or wrap is not listed in the specifications for low pressure round ductwork. Are any of these items required for low pressure round ductwork?

Suggestion: Additional cost for wrapping low pressure round duct is estimated at \$25,000. This cost increases if round duct is to be lined. IF liner is required, fittings and elbows will not be lined.

Response:

Wrap low pressure round ductwork with 1-inch thick fiberglass insulation same as medium pressure ductwork. There is a same chance that the conditions above ceilings could be at a dew point temperature that would condense on cold duct surface.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark Schaefer

Date: 8/3/2016