



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: August 01, 2016 **NO.:** RFI-228

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Curtainwall Sealant Colors

Response Required By: August 08, 2016

Drawing / Spec Reference:

Information Requested:

In spec 084423 page 7 the EGS 3 system is called out to be "Pewter" color. On the returned submittal 084423-011 there was a note "EGS-2A & EGS-3: Black color at all conditions".

On M17 of 084423-002 the original curtainwall mockup shows the dimension of 6 9/16" was changed to 5" which resulted in this becoming an EGS-3 condition.

Please verify the color at this location.

Response:

EGS-3 systems above level 02 to have system color and sealant color same as EGS-2 system.

EGS-3 systems below level 02 to be black color and have black color sealant at all locations.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 08/03/2016