



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: August 01, 2016 **NO.:** RFI-229

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Sump Pump Alarm Panels

Response Required By: August 08, 2016

Drawing / Spec Reference:

Information Requested:

Sheets P0101.A and P0111.A do not indicate the locations that the elevator sump pump alarm panels should be mounted at. Please clarify. Also, please verify that electrical power is available at these locations.

Response:

Locate alarm panels in Janitors Closet 175, connect alarm panels to same circuit as sump pump.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **Bill Shaw**

Date: **8/16/2016**
