



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** August 02, 2016 **NO.:** RFI-230

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Cable Tray Reduction

Response Required By: August 09, 2016

Drawing / Spec Reference:

Information Requested:

Is it acceptable to reduce the size of the cable tray from 24x4 down to 12x4 for the run of tray heading west of Data room 100B in level 1? We are unable to coordinate the 24" cable tray through Corridor C110, and still maintain reasonable access to the tray.

Response:

WE WILL ACCEPT 16" WIDE BASKET TRAY (12" DOES NOT ALLOW ENOUGH FUTURE GROWTH). THIS APPLIES TO LEVEL 01, AREA B ONLY (SHEET T0101.B).

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **Tom Becker, Faith Group**

Date: **8/8/16**