



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: August 02, 2016 NO.: RFI-231

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Penetrations in Beams for Fire Protection

Response Required By: August 09, 2016

Drawing / Spec Reference:

Information Requested:

The fire protection contractor would like to request the addition of a 4" diameter penetration in each of the four beam locations shown. This will allow for better hydraulics and balancing of the piping as well as eliminate the need for any sets in the sprinkler or heated piping which may require the addition of drains above the ceiling panels. If this is acceptable please confirm and Ahern will provide dimensioned locations

Response:

**THE SIZE AND LOCATIONS SHOWN ARE ACCEPTABLE. PENETRATIONS
MUST BE LOCATED IN THE MID-DEPTH OF THE BEAM AND FOLLOW
DETAIL 10/S0003. COORDINATE FOR SHOP FABRICATION.**

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **JILL WALKER / DMA**

Date: **8/3/2016**



NEW 4" DIA. BEAM PENETRATION

NEW 4" DIA. BEAM
PENETRATION

NEW 4" DIA. BEAM
PENETRATION

NEW 4" DIA. BEAM
PENETRATION

STAIR 1-2
0240