



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: August 08, 2016 **NO.:** RFI-238

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Architectural Ceiling note

Response Required By: August 15, 2016

Drawing / Spec Reference:

Information Requested:

Reference Sheet A0703.B note C.17

Note C.17 on sheet A0703.B is pointing to fixture types RCG15, RCG12, and both RCG9-9 fixtures. All these fixtures are specified grid flange... Will these fixtures be installed in drywall or in ceiling type APC - 2?

Response:

These fixtures will be installed in APC - 2, Grid flange is correct.

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman

Date: 08.09.16