



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: August 19, 2016 NO.: RFI-243

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Installing Vapor Retarder on Top of Granular Fill at Slab on Grade

Response Required By: August 26, 2016

Drawing / Spec Reference:

Information Requested:

1/S0002 shows the vapor retarder to be placed between the subgrade and compacted granular fill. To reach required compaction Paric proposes to install the vapor retarder on top of the granular fill.

Please advise if this is acceptable.

Response:

Acceptable

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **JILL WALKER / DMA**

Date: **8/22/2016**