



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: August 19, 2016 **NO.:** RFI-246

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: EMT Steel Compression / Set

Response Required By: August 26, 2016

Drawing / Spec Reference:

Information Requested:

Spec Section 261300 calls for using Steel Compression Connectors & Couplers and Spec Section 270528 calls for using Steel Set Screw Connectors & Couplers? Which are we to use Set Screw or Compression ? We would prefer to utilize steel set screw connectors and couplers.

Response:

Set screw connectors and couplers are acceptable so long as ground wires are pulled and the conduit system is not being used as a grounding path.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Bill Shaw

Date: 08/22/2016