



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** August 24, 2016 **NO.:** RFI-251

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Column cap plates

Response Required By: August 31, 2016

Drawing / Spec Reference:

Information Requested:

Please advise if cap plates will be required on all WF columns. 1/S304 indicates cap plates for columns in brace bays but no detail/weld is given.

Response:

CAP PLATES ARE TO BE PROVIDED AT BRACED FRAME COLUMNS, EDGE COLUMNS AND HSS COLUMNS. THE EDGE BENT PLATE IS INCORPORATED INTO THE CAP PLATE. CAP PLATES AT INTERIOR COLUMNS ARE NOT REQUIRED. ATTACHMENT SHALL BE 2" LONG - 1/4" FILLET WELDS AT THE FOUR CORNERS OF THE COLUMN UNLESS OTHERWISE REQUIRED BY THE CONNECTION DESIGNER FOR THE BRACED FRAME CONNECTIONS.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 8/24/2016