



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: August 30, 2016	NO.: RFI-259
--------------------------------	------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Paver clarification in ASI 03

Response Required By: September 06, 2016

Drawing / Spec Reference:

Information Requested:

A0507.A in ASI 03 adds 24"x48" pavers along the stairs south of the green roof. Please provide additional clarification on how these will tie in to the 21"x24" pedestal pavers along the green roof shown on L400.

Response:

All pavers in this area are 12" x 24" size.
See detail below for additional information on paver transition.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Felipe DeNarvaez, PLA

Date: 09/09/2016

