



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

**REQUEST FOR INFORMATION**      **DATE:** September 01, 2016      **NO.:** RFI-264

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building      Project No.: 15051

Subject: Confirm Floor Cleanout Type in Level 0

Response Required By: September 08, 2016

Drawing / Spec Reference:

**Information Requested:**

Please confirm if the floor cleanouts in level 0 are to be FCO-1 or FCo-2 types

**Response:**

.

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Level 0 floor clean outs are to be FCO-1. This type is to be used in all service, mechanical and unfinished areas.

Answered By: Mike Whitworth - WES

Date: September 05, 2016