



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 07, 2016 NO.: RFI-268

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Additional Information at BA Light Fixtures

Response Required By: September 14, 2016

Drawing / Spec Reference:

Information Requested:

The lighting contractor needs a detailed dimensioned layout of the type BA stairwell fixtures including lengths and angles to release materials for fabrication.

The light fixture schedule calls for wall mounted lights, however these appear to be recessed in a wood ceiling per 8/A0501.B . Please confirm

Detailed dimensioned layout:

See diagram 2 on sheet E0201.B for design intent. Per Light Fixture Schedule Keyed Note 11, submit detailed custom shop drawings for review. Coordinate lights with the stair contractor and stair shop

Response: drawings in order to determine the final lengths and geometry.

Recessed Vs Wall mounted:

Refer to previous response on RFI-237. Provide recessed version of the fixture. For previously submitted Finelite product. this would be "HP4-R" series in-lieu of "HP4-WM" series fixtures.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente (William Tao & Associates)

Date: 09/08/2016