



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 12, 2016 **NO.:** RFI-277

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Guardrail Joint Detail 3/.A0508.E

Response Required By: September 19, 2016

Drawing / Spec Reference:

Information Requested:

Provide at guardrail joint detail bolt size and quantity. Note: 1/4" Diameter CS bolt has minimum length of 5/16".

Response:

We would like to discuss the possible splice details.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: **Kelvin Patel & Lynn Grossman**

Date: **09/20/2016**

POWDER
D RAILING
BLY - 3/8 GALV
RAIL CAP .

RAILING JOINT:
PROVIDE OVERLAP W/
CS SCREW FROM
BOTTOM (SLIP JOINT)

TOP OF GUARD
TO MATCH TOP

3/8"

POWDER
D RAILING
BLY - 3/8" GALV
BALUSTERS - EQ
G 4 1/4" O.C. MAX

