



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 12, 2016 NO.: RFI-279

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Guardrail For Retaining Wall Along Line 8

Response Required By: September 19, 2016

Drawing / Spec Reference:

Information Requested:

We are to use a similar to Detail 11/A0511, this detail shows the guardrail on top of a channel. Assuming we are to use the same material for pickets, posts and rails, Verify the bottom rail is 3" above top of wall and the 3/4X1-1/2 posts are to extend into the retaining wall 7"(8" block out) with a maximum spacing of 48" or provide new detail.

Response:

The proposed use of detail is only acceptable for the guardrails on the retaining walls east of column line 8.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 09/20/2016