



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 12, 2016 NO.: RFI-282

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Mounting Heights of Devices

Response Required By: September 19, 2016

Drawing / Spec Reference:

Information Requested:

Which take precedence, the mounting heights of devices found on Architectural sheet A0002 or what is found in the electrical spec 260100-13?

Response:

Electrical specification 260100-13 takes precedence.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 09/23/2016