



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** September 15, 2016 **NO.:** RFI-283

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Storefront door hardware group numbers not matching floor plan

Response Required By: September 22, 2016

Drawing / Spec Reference:

Information Requested:

Storefront door hardware spec 087100.01 identifies doors X201.2, X201.3, X200A.2, and XC250A.1 in hardware groups 3,4, and 5. We have been unable to identify these door numbers in the architectural drawings.

Please advise correct door numbers.

Response:

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Wow - we had to go into the archives to sort this one out! Attached is the marked-up hardware schedule

X201.1 = XC270A.1

X202.2 = XC270A.2

X200A.2 = XC250

XC250A.1 = XC230

Answered By: Lynn Grossman

Date: 09.15.16

**Interdisciplinary Science Building
Webster University
Cannon Design Project No. 004561.01**

2. Submit a signed, written final report as specified in Section 1.3 - SUBMITTALS.
3. Contractor shall correct all deficiencies and schedule a reinspection of fire door assemblies which were noted as deficient on the inspection report.
4. Inspector shall reinspect fire door assemblies after repairs are made.
5. Additional reinspections which are required due to incomplete repairs will be performed by the inspector at the expense of the Contractor.

3.3 DOOR HARDWARE SCHEDULE

HARDWARE GROUP NO. 01
FOR USE ON MARK/DOOR #(S):
XC130

EACH TO HAVE:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
1	EA	PIVOT SET	7215 SET [COLOR TO MATCH STOREFRONT]	626	IVE
2	EA	INTERMEDIATE PIVOT	7215 INT [COLOR TO MATCH STOREFRONT]	626	IVE
1	EA	POWER TRANSFER	EPT10 CON	689	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL+-33A-NL-OP-388-CON	626	VON
1	EA	MORTISE CYLINDER	26-064	626	SCH
1	EA	PRIMUS CORE	20-740	626	SCH
1	EA	90 DEG OFFSET PULL	8190HD 10" O	630	IVE
1	EA	SURFACE CLOSER	4040XP SCUSH MC	689	LCN
1	EA	THRESHOLD	657A-V3-226	A	ZER
1	EA	CREDENTIAL READER	BY ACCESS CONTROL		B/O
1	EA	DOOR CONTACT	679-05HM	BLK	SCE
1	EA	POWER SUPPLY	PS904 900-4RL	LGR	VON

NOTE: SEALS AND SWEEPS BY STOREFRONT MANUFACTURER.
OPERATION: VALID CREDENTIAL OR AUTOMATED ACCESS CONTROL TO RETRACT
ELECTRIFIED LATCHING ALLOWING ENTRY. FREE EGRESS AT ALL TIMES.

HARDWARE GROUP NO. 02
FOR USE ON MARK/DOOR #(S):
XC153

EACH TO HAVE:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
2	EA	PIVOT SET	7215 SET	626	IVE
4	EA	INTERMEDIATE PIVOT	7215 INT	626	IVE
1	EA	PANIC HARDWARE	3349A-EO	626	VON
1	EA	PANIC HARDWARE	3349A-NL-OP-388	626	VON
1	EA	MORTISE CYLINDER	26-064	626	SCH
1	EA	PRIMUS CORE	20-740	626	SCH
2	EA	90 DEG OFFSET PULL	8190HD 10" O	630	IVE
2	EA	SURFACE CLOSER	4040XP SCUSH MC	689	LCN
1	EA	THRESHOLD	657A-V3-226	A	ZER

NOTE: SEALS, ASTRAGAL, AND SWEEPS BY STOREFRONT MANUFACTURER.

**Interdisciplinary Science Building
Webster University
Cannon Design Project No. 004561.01**

HARDWARE GROUP NO. 03
FOR USE ON MARK/DOOR #(S):

~~X201.2~~ ~~X201.3~~
XC 270A.1 **XC 270A.2**

EACH TO HAVE:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
2	EA	PIVOT SET	7215 SET	626	IVE
4	EA	INTERMEDIATE PIVOT	7215 INT	626	IVE
1	EA	POWER TRANSFER	EPT10 CON	689	VON
1	EA	PANIC HARDWARE	3349A-EO	626	VON
1	EA	ELEC PANIC HARDWARE	RX-3349A-NL-OP-388	626	VON
1	EA	MORTISE CYLINDER	26-064	626	SCH
1	EA	PRIMUS CORE	20-740	626	SCH
2	EA	90 DEG OFFSET PULL	8190HD 10" O	630	IVE
1	EA	SURFACE CLOSER	4040XP SCUSH MC	689	LCN
1	EA	SURF. AUTO OPERATOR	4642 WMS	689	LCN
2	EA	ACTUATOR, WALL MOUNT	8310-853T	630	LCN
1	EA	THRESHOLD	657A-V3-226	A	ZER

NOTE: SEALS, ASTRAGAL, AND SWEEPS BY STOREFRONT MANUFACTURER.

OPERATION: WHEN ACTIVE LEAF IS MECHANICALLY DOGGED, RX SWITCH TO ALLOW ACTUATORS TO BE ACTIVE. PRESSING ACTUATOR WHEN ACTIVE CYCLES ACTIVE LEAF. WHEN ACTIVE LEAF IS UNDOGGED, RX SWITCH TO SHUNT ACTUATORS. DOGGING EXIT DEVICES ALLOWS PUSH/PULL OPERATION OF DOORS. FREE EGRESS AT ALL TIMES.

HARDWARE GROUP NO. 04
FOR USE ON MARK/DOOR #(S):

~~XC200A.2~~ **XC 250**

EACH TO HAVE:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
2	EA	PIVOT SET	7215 SET	626	IVE
2	EA	INTERMEDIATE PIVOT	7215 INT	626	IVE
1	EA	POWER TRANSFER	EPT10 CON	689	VON
1	EA	PANIC HARDWARE	3349A-EO	626	VON
1	EA	ELEC PANIC HARDWARE	RX-3349A-NL-OP-388	626	VON
1	EA	MORTISE CYLINDER	26-064	626	SCH
1	EA	PRIMUS CORE	20-740	626	SCH
2	EA	90 DEG OFFSET PULL	8190HD 10" O	630	IVE
1	EA	SURFACE CLOSER	4040XP SCUSH MC	689	LCN
1	EA	SURF. AUTO OPERATOR	4642 WMS	689	LCN
2	EA	ACTUATOR, WALL MOUNT	8310-853T	630	LCN
1	EA	THRESHOLD	657A-V3-226	A	ZER

**Interdisciplinary Science Building
Webster University
Cannon Design Project No. 004561.01**

NOTE: SEALS, ASTRAGAL, AND SWEEPS BY STOREFRONT MANUFACTURER.

OPERATION: WHEN ACTIVE LEAF IS MECHANICALLY DOGGED, RX SWITCH TO ALLOW ACTUATORS TO BE ACTIVE. PRESSING ACTUATOR WHEN ACTIVE CYCLES ACTIVE LEAF. WHEN ACTIVE LEAF IS UNDOGGED, RX SWITCH TO SHUNT ACTUATORS. DOGGING EXIT DEVICES ALLOWS PUSH/PULL OPERATION OF DOORS. FREE EGRESS AT ALL TIMES.

HARDWARE GROUP NO. 05
FOR USE ON MARK/DOOR #(S):

~~XC250A.1~~ **XC 230**

EACH TO HAVE:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
1	EA	PIVOT SET	7215 SET [COLOR TO MATCH STOREFRONT]	626	IVE
1	EA	INTERMEDIATE PIVOT	7215 INT [COLOR TO MATCH STOREFRONT]	626	IVE
1	EA	ELEC PANIC HARDWARE	RX-33A-NL-OP-388	626	VON
1	EA	MORTISE CYLINDER	26-064	626	SCH
1	EA	PRIMUS CORE	20-740	626	SCH
1	EA	90 DEG OFFSET PULL	8190HD 10" O	630	IVE
1	EA	SURF. AUTO OPERATOR	4642 WMS	689	LCN
2	EA	ACTUATOR, WALL MOUNT	8310-853T	630	LCN
1	EA	THRESHOLD	657A-V3-226	A	ZER

NOTE: SEALS AND SWEEPS BY STOREFRONT MANUFACTURER.

OPERATION: WHEN EXIT DEVICE IS MECHANICALLY DOGGED, RX SWITCH TO ALLOW ACTUATORS TO BE ACTIVE. PRESSING ACTUATOR WHEN ACTIVE CYCLES DOOR LEAF. WHEN EXIT DEVICE IS UNDOGGED, RX SWITCH TO SHUNT ACTUATORS. DOGGING EXIT DEVICE ALLOWS PUSH/PULL OPERATION OF DOOR. FREE EGRESS AT ALL TIMES.

END OF SECTION 087100.01