



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** September 19, 2016 **NO.:** RFI-286

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: OD-2 drain type

Response Required By: September 26, 2016

Drawing / Spec Reference:

Information Requested:

P0601 shows the OD-1 roof drain type but does not provide a spec for the OD-2 type. Please provide.

Response:

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Plumbing drawing P0105.B shows incorrectly RD-2 and OD-2 for the Level 03 roof.
These both should read RD-1 and OD-2.
This will be addressed in an ASI.

Answered By: Mike Whitworth - WES

Date: September 22, 2016