



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 19, 2016 NO.: RFI-288

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Top of concrete elevation clarification

Response Required By: September 26, 2016

Drawing / Spec Reference:

Information Requested:

On drawing S0103, along column line 7 a cut on this foundation wall shows detail 14/S0300 which indicates a concrete ledge to be formed 1'-4" below Level 2 finish floor elevation of 100'-00". This dimension does not coordinate with the architectural dimension of 1'-8" below Level 02 finish floor which is shown on A0313. Please advise which dimension is correct.

Response:

DIMENSION IS 1'-4" PER 14/S0300

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 9/21/2016