



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 22, 2016 NO.: RFI-292

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Wall clarification on S0101

Response Required By: September 29, 2016

Drawing / Spec Reference:

Information Requested:

On column line 5 there are 2 details describing wall construction. 11/S0200 shows the inside face of wall 8 1/2" from 1.6 line and 1/S0300 shows the inside face of wall 7 1/2" from 5 line, please confirm 1/S0300 is accurate. Please confirm this dimension will also work with 15' 8 1/2" radius shown.

Response:

1/S0300 is correct. Line 5 & C.3 have a dimension of 1'-9 1/2" from CL to outside face of concrete. The radius of 15'-8 1/2" aligns with these dimensions. The dimension along grid 1.6 is 1'-10 1/2". As these walls are poured, please confirm the construction matches this information.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 9/23/2016