



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** September 26, 2016 **NO.:** RFI-299

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Wiremold 4000 Series Raceway

Response Required By: October 03, 2016

Drawing / Spec Reference:

Information Requested:

The specified CAT 6A data cable and jack will not fit with the specified 4000 series raceway. There are (2) solutions

Suggestion: Solution # 1... The 4000 series Wiremold would have to be changed to a 6000 series raceway. This would create a cost impact.

Solution # 2... We would need to investigate a different cable and jack solution for this project. This may or may not create a cost impact.

Response:

We prefer to not change the raceway series or cable manufacturer. We recommend using the shallower Ortronics Clarity Cat6A jack (OR-TJ6A) with the Wiremold 4047 series device plate. The jacks will need to adhere to the specified color requirements and may only be used in the 4000 series raceway applications.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: David Caputo, Faith Group

Date: Rev1: 09/29/2016