



**PARIC CORPORATION**  
77 Westport Plaza Suite 250  
St. Louis, MO 63146  
TEL: 636-561-9500  
FAX: 636-561-9501

**REQUEST FOR INFORMATION**      **DATE:** September 28, 2016      **NO.:** RFI-307

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building      Project No.: 15051

Subject: Drain tile at North portion of Area A

Response Required By: October 05, 2016

Drawing / Spec Reference:

**Information Requested:**

Please advise if the drain tile at the North portion of Area A should be installed at the base of the wall in lieu of the designed plumbing elevations on P0011 (see attached).

**Response:**

*Response from Scott Klingsick, KWK Architects (datd October 06, 2016)*

*We would prefer the top of the drain pipe not be higher than the top of grade beam. If this cannot be done without reducing the slope then it would be acceptable to have the flow line of the pipe at the top of the grade beam. The contractor will need to take extreme care during installation to ensure the slope is true and accurate. We do not want water accumulating at the top of the grade beam. Thanks*

**ARCHITECT'S RESPONSE:**

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Submitted By: Mike Whitworth - WES

Date: 10-06-16

