



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** September 28, 2016 **NO.:** RFI-309

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science
Building

Project No.: 15051

Subject: Water Supply and Drainage

Response Required By: October 05, 2016

Drawing / Spec Reference:

Information Requested:

Plan sheets: P0103.A, P0113.A, A0615 Detail 16

Plumbing sheet P0103.A doesn't call for a water supply, and P0113.A doesn't show a floor sink serving the Autoclave shown on the Lab Equipment plan in Room 372B. Is a water supply and/or Floor Sink or other drainage provision required for this Autoclave?

Response:

A water supply and floor sink will be required.
This will be addressed in an upcoming ASI.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Whitworth - WES

Date: 10-06-16