



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** September 28, 2016 **NO.:** RFI-310

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Joe Voypick

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Countertop Drainage Key Notes

Response Required By: October 05, 2016

Drawing / Spec Reference:

Information Requested:

Plan Sheets: A0204, P0102.A, P0112.A

There are no keyed notes for drainage or water supply for the countertop Autoclave in Room 289A. Please advise if drainage and/or domestic water supply are required for this equipment

Response:

A water supply and floor sink will be required.
This will be addressed in an upcoming ASI.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mike Whitworth - WES

Date: 10-06-16