



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION DATE: September 29, 2016 NO.: RFI-312

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Millwork clarifications

Response Required By: October 06, 2016

Drawing / Spec Reference:

Information Requested:

5/A0607 calls out for 064023 PLAM CABINETS –White. Finish schedules for the corresponding teaching walls (276, 284, 291, 378, 383, 388, 391, 472, 483, 488, and 492) call out for CSW-1, which is in spec section 123553 – Laboratory Casework.

There is a similar situation for the Teaching Wall Type-2 (6/A0607). Elevation calls out for PLAM Cabinets, Finish Schedule calls out for Laboratory Casework. This happens in rooms 284 and 480.

Suggestion: Please advise on material.

Response:

AS NOTED ON THE DRAWINGS (5/A0607 & 6/A0607), ALL THE BASE CABINETS AT THE TEACHING WALL ARE TO BE WHITE PLAM CABINETS.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 10/04/2016