



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: September 29, 2016	NO.: RFI-313
--------------------------------	---------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Electrical detail clarification

Response Required By: October 06, 2016

Drawing / Spec Reference:

Information Requested:

On sheets E101.B, E102.B, E103.B and E104.B there are details that look like a fan but are shown but on the panel schedule they are noted as fire door. All (4) of these set on there respective floor near the electrical rooms. See attached drawing, please clarify what this detail represents.

Response: The symbol indicated is a motor symbol and represents the motor for the fire door. Also, reference keyed note E68 for associated smoke alarm and door hold open as well as the door schedule and additional details on the Architectural drawings.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Bill Shaw

Date: 10/03/2016

