



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 06, 2016	NO.: RFI-317
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Pilaster dimensions

Response Required By: October 13, 2016

Drawing / Spec Reference:

Information Requested:

On drawing S0101, the pilasters at 7.2, 7.3, 7.4, F.1 and F.3 are shown to be 2 1/4" from the concrete wall. On drawing S0504 detail 1 shows the front of the pilaster 2 3/4" from the concrete wall. Which dimension is correct? It is acceptable to pour the concrete wall at the radius, thickened to the face of the pilaster from column line 7.3 to F.1?

Response:

The dimension from col centerline to grid varies slightly from 7 1/8" to 7 1/4" due to the skews and rounding. The offset for the pilasters is intended to be 2 1/4". Detail 1/S0504 requires revision. Place wall as shown with pilasters - do not thicken wall.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 10.10.2016