



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 07, 2016	NO.: RFI-319
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Flashing detail at 1/A452

Response Required By: October 14, 2016

Drawing / Spec Reference:

Information Requested:

Please identify the component or material as indicated in Detail 1/A452 at the base of the wall extending over the top of the foundation insulation.

Response:

The flashing at the below grade water proofing is 26 ga. stainless steel metal flashing.
Detailed 6/A0457 shows a similar flashing.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: _____

Date: **10/11/2016**

CONFORMED SET 01 JUL 2016

1 ADDENDUM 1-1 29 JAN 2016
ISSUED FOR CONSTRUCTION (BP1) 15 JAN 2016

No.	Description	Date

Drawing Title:

**EXTERIOR SECTION
DETAILS**

Project No.: 04561.01 Checked by:

A0452

© Cannon Design 2015

