



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 07, 2016	NO.: RFI-320
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Performing full weld on beams

Response Required By: October 14, 2016

Drawing / Spec Reference:

Information Requested:

The steel beams that tie into the wall along C.3 line are approximately 1" too short due to the conflict addressed in RFI 292. Paric requests to perform a full weld from the tab to the beam in lieu of bolts at these locations. Please advise if this will be acceptable and provide additional details if needed.

Response:

This approach is acceptable, however, the connection design engineer should be made aware due to the additional eccentricity in the connection. All of these connections are beams - no girders with higher loads are involved - therefore I anticipate the angles provided for bolted connections will be acceptable for welding.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: JILL WALKER / DMA

Date: 10.10.2016



