



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 14, 2016	NO.: RFI-323
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Power requirements for autoclaves

Response Required By: October 21, 2016

Drawing / Spec Reference:

Information Requested:

The power requirements for the Autoclave listed in the equipment schedule is 208v. The panel schedule call out for it to be 480V. Please advise how to proceed.

Response:

Provide 480 volt configuration and power as indicated on electrical drawings.
Disregard 208 volt requirement indicated on equipment schedule.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 10/17/16