



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 14, 2016	NO.: RFI-324
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Solid surface countertops

Response Required By: October 21, 2016

Drawing / Spec Reference:

Information Requested:

ID0203 calls out countertop SSF-1 in spec section 123661.16. This countertop is a HI-MACS product by LG HAUSYS. Per the current construction documents, there are no SSF-1 countertops in the scope of work. ID0201 and ID0202 do not call out for SSF-1 in any of the rooms. Please confirm that this is the design intent and that spec section 123661.16 is not being used on this project.

Response:

.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

SSF-1 was added with ASI 006. ASI 006 notes that SSF-1 is for the bench in the BioVestibule 183C adjacent to the cadaver lab.

Answered By: Lynn Grossman

Date: 10.18.16