



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 14, 2016	NO.: RFI-325
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name:	15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---------------	---	--------------------

Subject: Dove tail slots for masonry

Response Required By: October 21, 2016

Drawing / Spec Reference:

Information Requested:

Please confirm there are to be no dove tail slots for the masonry on this project.

Response:

Dove tail slots are called for masonry veneer at the concrete backup wall for the dumpster enclosure only.

We would be open to alt. suggestions at the dumpster but dovetails would be easier – if the backup wall is concrete.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Kelvin Patel

Date: 10/18/2016