



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION **DATE:** October 17, 2016 **NO.:** RFI-327

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building Project No.: 15051

Subject: Fireproofing at Level 0 shaft

Response Required By: October 24, 2016

Drawing / Spec Reference:

Information Requested:

2/G0301 shows fireproofing in the area to be used as a vent for the mechanical systems. This would end up with fireproofing material in the air flow.

Suggestion: Paric proposes to fireproof as shown but cover the inside of the beams with a sealed sheet metal solution. Please advise if this is acceptable and provide a sketch if needed.

Response:

Yes, sheet metal sleeves between fireproofed structure is acceptable as long as the opening for airflow is as large as possible (57 sq. ft. was the minimum size we accepted).
Please advise if a sketch is required.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark Schaefer

Date: 10/17/2016

