



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 19, 2016	NO.: RFI-331
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Power for video monitors in lecture hall

Response Required By: October 26, 2016

Drawing / Spec Reference:

Information Requested:

In ASI - 30 in lecture hall 160 note # 23 sheet on T0101.B refers to a video monitor wall. There is no electric shown on sheet E0101.B to feed these video monitors? Please advise if power needs to be added.

Response:

See RFI-334 for upcoming response.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Mark de la Fuente, WTA

Date: 10/25/16