



PARIC CORPORATION
77 Westport Plaza Suite 250
St. Louis, MO 63146
TEL: 636-561-9500
FAX: 636-561-9501

REQUEST FOR INFORMATION	DATE: October 21, 2016	NO.: RFI-333
--------------------------------	-------------------------------	---------------------

To: Cannon Design

Attn: Kelvin Patel

From: Paric Corporation

Requested By: Devin Gates

Project Name: 15051-Webster University Interdisciplinary Science Building	Project No.: 15051
---	--------------------

Subject: Lighting at rooms 452, 454, and 456

Response Required By: October 28, 2016

Drawing / Spec Reference:

Information Requested:

Please confirm the lighting types at rooms 452, 454, and 456.

Response:

The ceiling heights in these rooms are too low to accommodate Type PA4 fixtures.
Provide Type RA4 fixtures as indicated on plans.

Lower ceiling in room 452 to allow recessed lights to pass below W14 roof framing. See attached.

ARCHITECT'S RESPONSE:

This information is provided as an interpretation of the Contract Documents for implementation. It is not an authorization for change to the Contract Sum or Contract Time. If this information results in a claim for a change to the Contract, the Contractor shall notify the [Construction Manager][Architect] of a change through the change process.

Answered By: Lynn Grossman, CannonDesign
Mark de la Fuente, WTA

Date: 10.26.16
10/26/16

